

INFORMATION REPORT

CD NO.

Country: (Information Zone)

DATE: 11-11-1951

PLACE
ACQUIRED

NO. OF ENCLS.
(LISTED BELOW)

DATE OF
INFO.

November -- December 1951

SUPPLEMENT TO
REPORT NO.

25X1

25X1

THIS DOCUMENT CONTAINS INFORMATION AFFECTING THE NATIONAL DEFENSE
OF THE UNITED STATES. WITHIN THE MEANING OF TITLE 18, SECTION 793
AND 794, OF THE U. S. CODE, AS AMENDED. ITS TRANSMISSION OR REVEL-
ATION OF ITS CONTENTS TO OR RECEIPT BY AN UNAUTHORIZED PERSON
IS PROHIBITED BY LAW. THE REPRODUCTION OF THIS FORM IS PROHIBITED.

THIS IS UNEVALUATED INFORMATION

25X1

In about mid-November 1951, four 12-ton boilers in the Power Plant in
Finow broke down as a result of drum damage. Repair was initiated at
once. A slight coal dust explosion caused some damage in early December
1951. No persons were injured. *

* ☐ Comment. The power plant in Finow belongs to the VVB-Energie-Mitte.
All the equipment of this plant was dismantled by the Soviets who left only
equipment which had been installed prior to World War I. The rated output
of the plant was 36 Mw, the actual output was 32 Mw. Frequent production
failures result because the plant is required to burn lignite instead of
hard coal, for which the plant was designed.

CLASSIFICATION ~~SECRET~~

STATE	#	<input checked="" type="checkbox"/>	NAVY	<input checked="" type="checkbox"/>	NSRB														
ARMY	#	<input checked="" type="checkbox"/>	AIR	#	<input checked="" type="checkbox"/>	FB													